

Addendum

Tender No:- TENDER No. RCB/BSL-III/04-02/01/NIT-05/2024-25

Tender Name:- Design, Supply, Fabrication and fixing work of MS structure support and Exhaust chimney pipe for 4x 500 KVA DG set installed at BSL-III Building in NCR Biotech Science Cluster Faridabad.

Following are the clarifications for pre bid meeting held on 22.07.2024.

S.No	Observation	Remarks
01	As per reputed manufactures of DG Sets. Two sets of DG exhaust pipe should not be inter connected.	Point accepted. Separate exhaust of each DG Set can be installed.
02	Certificate from pollution control board and other agency is not required as this work is for installation of pipes and support structure.	Point accepted.

-Sd xxx-