

CORRIGENDUM

Tender No: RCB/04-01/62/2016-17

Work: Supply, Laying, testing and commissioning of 3.5 Core x 300 Sq mm Aluminium XLPE Armoured Power Cable from ESS to SAF.

Item No 4 of Schedule of work may be read as following.

Supply, installation, testing and commissioning of Air Circuit Breaker, Make – L&T, Model CN- CS 800 A, **4 Pole** , Icu&Ics- 65 KA, Utilization Cat B Manually Charging and draw out type, or its upgraded version.

Other terms and condition of tender remain unchanged.